

Fire & Water Safety

APPENDIX-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

DATED:

It is certified that an inspection team headed by Mr. Suresh Thakur A.E.

(Name of Officers with designation) from Jal Shakti Vishay

(Name of Department/Office) inspected the Govt. G. Sec. School Khera

(Name & Address of the school) on 29/09/2025 (date of inspection) and found that the G. S. S. Khera (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/U.T Govt.

The above is valid for a period of One year i.e. date of issue of certificate.

Assistant Engineer

Signature with Seal: Jal Shakti Sub Division Saloni 29/09/2025

Name: Mr. Suresh Thakur

Designation: Assistant Engineer

Name & Address of the Office /Department

Jal Shakti Vishay
Sub division Saloni
Distt. Chamba (H.P.)

To

The Principal

Govt. G. Sec. School Khera

(Name & Address of the Institution)

Himachal Pradesh Jal Shakti Vibhag

Sub Divisional Water Testing Laboratory, Salooni
TEST REPORT

058

Sample No. 25019

Dated:- 27/09/2025

Test Report No. SDWTL-Salooni-2023/

Date:- 27/09/2025

Name and Address of Customer: AE Salooni

Sampling method: -

Condition of Sample when Received: OK
Name of Source/Scheme: WSS Sarog Chameeta

Sample Description:

Sample Quantity: 400ml

Collected on: - 27/09/2025

Test Start Date: 27/09/2025

Test End Date: 29/09/2025

Name of Panchayat: Kihaz

Name of Habitation: Sarog

Name of Village: Sarog

Type of Source: Spring

Sr. No.	Test	Test Method	Result	Requirement As per IS 10500-2012	
				Acceptable Limit	Permission limit in the absence of alternate source
Physical Parameters					
1.	Colour	APHA 23 rd Edition/IS 2120 Method B	5 HU	5HU	15 U
2.	Odour	APHA 23 rd Edition/IS 3025(Part 5)	Agreeable	Agreeable	Agreeable
3.	Taste	APHA 23 rd Edition/IS 3025(Part 7&8)	Agreeable	Agreeable	Agreeable
4.	pH	APHA 23 rd Edition/IS 3025(Part 11)	7.34	6.5-8.5	No relaxation
5.	Turbidity	APHA 23 rd Edition/IS 3025(Part 10)	0 NTU	1NTU Max	5NTU Max
Chemical Parameters					
6.	TDS	APHA 23 rd Edition/IS 2540-C	96 mg/l	500 mg/lmax	2000 mg/lmax
7.	Total Hardness as CaCo3	APHA 23 rd Edition/IS 3025(Part 21)	90 mg/l	200 mg/lmax	600 mg/lmax
8.	Calcium	APHA 23 rd Edition /3500-Ca. B	26.05 mg/l	75 mg/lmax	200 mg/lmax
9.	Magnesium	APHA 23 rd Edition /3500-MG.B	15.53 mg/l	30 mg/lmax	100 mg/lmax
10.	Total Alkalinity	APHA 23 rd Edition/IS 3025(Part 23)	80 mg/l	200 mg/lmax	600 mg/lmax
11.	Chlorides (as Cl)	APHA 23 rd Edition/IS 3025(Part 32)	33.67 mg/l	250 mg/lmax	1000 mg/lmax
12.	Free Residual Chlorine				
Bacteriological Parameters					
13	Total Coli forms	IS 1622:1981(reaffr.)	Nil	Nil	Nil
14	E-Coli	IS 1622:1981(reaffr.)	Nil	Nil	Nil

Note:

- BDL :- Below the Detection Limit.
- This report should not be produced partly of full without approval of signatory authority for legal purpose.
- The results refer only to tested samples and parameters tested.



Junior Engineer
Jal Shakti Section

Assistant Engineer
Jal Shakti Sub-Division